

217/782-2113

"REVISED"
LIFETIME OPERATING PERMIT

PERMITTEE

Snap-On Tools Company
Attn: Greg Cunningham
3011 East Route 176 Doc C
Crystal Lake, Illinois 60014

<u>Application No.:</u> 75030037	<u>I.D. No.:</u> 111813AAF
<u>Applicant's Designation:</u>	<u>Date Received:</u> September 5, 2000
<u>Subject:</u> Boilers	
<u>Date Issued:</u> November 27, 2000	<u>Expiration Date:</u> See Condition 1.
<u>Location:</u> 3011 East Route 176, Crystal Lake	

This permit is hereby granted to the above-designated Permittee to OPERATE emission unit(s) and/or air pollution control equipment consisting of:

Boiler #1, Johnson-Reliance 16.74 mmBtu/Hr Natural Gas Unit
Boilers #2 and #3, Johnson-Birchfield Each 17.85 mmBtu/Hr Natural Gas Units

pursuant to the above-referenced application. This permit is subject to standard conditions attached hereto and the following special condition(s):

- 1a. This permit shall expire 180 days after the Illinois EPA sends a written request for the renewal of this permit.
- b. This permit shall terminate if it is withdrawn or is superseded by a revised permit.
2. Emissions and operation shall not exceed the following limits:

Natural Gas Boilers	Usage (mmscf/Yr)	PM	Emissions (Tons/Yr)			
			SO ₂	NO _x	CO	VOM
#1, #2, and #3	16	0.02	0.01	0.80	0.67	0.04

Compliance with the above limits shall be determined from the required records and standard emission factors. Compliance with the annual limits shall be determined monthly using the last 12 months of data

3. The Permittee shall maintain monthly records of the following items:
 - a. The total amount of natural gas burned.
4. All records and logs required by this permit shall be retained at a readily accessible location at the source for at least three years from the date of entry and shall be made available for inspection and copying by the Illinois EPA upon request. Any records retained in an electronic format (e.g., computer) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an Illinois EPA request for records during the course of a source inspection.

5. If there is an exceedance of the requirements of this permit as determined by the records required by this permit, the Permittee shall submit a report to the Illinois EPA's Compliance Section in Springfield, Illinois within 30 days after the exceedance. The report shall include the emissions released in accordance with the recordkeeping requirements, a copy of the relevant records, and a description of the exceedance or violation and efforts to reduce emissions and future occurrences.
6. Two (2) copies of required reports and notifications concerning equipment operation or repairs, performance testing or a continuous monitoring system shall be sent to:

Illinois Environmental Protection Agency
Division of Air Pollution Control
Compliance Section (#40)
P.O. Box 19276
Springfield, Illinois 62794-9276

and one (1) copy shall be sent to the Illinois EPA's regional office at the following address unless otherwise indicated:

Illinois Environmental Protection Agency
Division of Air Pollution Control
9511 West Harrison
Des Plaines, Illinois 60016

7. Persons with lifetime operating permits must obtain a revised permit for any of the following changes at the source:
 - a. An increase in emissions above the amount the emission unit or the source is permitted to emit;
 - b. A modification;
 - c. A change in operations that will result in the source's noncompliance with conditions in the existing permit; or
 - d. A change in ownership, company name, or address, so that the application or existing permit is no longer accurate.

It should be noted that the 40 Hp Sellers boilers are exempt from state permit requirements, pursuant to 35 Ill. Adm. Code 201.146(d).

If you have any questions on this permit, please contact Jim Cobb at 217/782-2113.

Donald E. Sutton, P.E.
Manager, Permit Section
Division of Air Pollution Control

DES:JDC:jar

cc: Region